

ADDENDUM NO.3

March 4, 2024

Richland-Bean Blossom C.S.C.

Including:

Edgewood High School - Additions and Renovations

Early Childhood Center

Intermediate School Renovations

Primary School Renovations

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications and the Drawings dated January 31, 2024, by Lancer Associates Architecture. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 3-1.

A. SPECIFICATION SECTION 01 12 00 – MULTIPLE CONTRACT SUMMARY

1. 3.03 / H. Bid Category #8 – Metal Studs, Drywall and Ceilings

Add the following Clarification:

6. At all locations receiving new ceramic wall tile over metal stud construction, including but not limited to kitchens, toilet rooms and drinking fountains, provide moisture resistant Gypsum Board per 09 21 16 / 2.2 / E / 3 for use as tile backer.

B. SPECIFICATION SECTION 09 21 16 – GYPSUM BOARD ASSEMBLIES:

Delete 2.3 / H.

C. SPECIFICATION SECTION 09 30 00 – TILING:

Delete all reference to Tile Backer Board.