

# ADDENDUM NO. 2

**April 26, 2024**

**Richland-Bean Blossom C.S.C.**

**RE-BID of BC07 – Aluminum Windows, Entrances & Storefronts**

**Including:**

**Edgewood High School - Additions and Renovations**

**Early Childhood Center**

**Intermediate School Renovations**

**Primary School Renovations**

**TO: ALL BIDDERS OF RECORD**

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications and the Drawings dated January 31, 2024, by Lancer Associates Architecture. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 1-1 and Lancer Associates Architecture Addendum No. 2 dated April 26, 2024.

**A. SPECIFICATION SECTION 01 12 00 – MULTIPLE CONTRACT SUMMARY**

**G. Bid Category No 7 – aluminum Windows, Entrances and Storefronts.**

- a. Clarifications: 4. Sliding transaction window at Room B102 is by this specification section.

**ADDENDUM NO. TWO**

**PROJECT:** Richland-Bean Blossom C.S.C. RE-BID of BC07 – Aluminum Windows, Entrances & Storefronts

**PROJECT NUMBER:** 23117

**DATE OF ADDENDUM:** 2024.04.26



**THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND IS ISSUED IN ACCORDANCE WITH THE INSTRUCTIONS TO BIDDERS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING THE ADDENDUM ACKNOWLEDGMENT SECTION OF THE BID FORM.**

**QUESTIONS**

**Q:** On drawing A601. Door D6 has 3 mid-rails. On drawing A603 door D6 has 4 mid-rails. Which is correct?

**A:** Provide 3 Mid-rails aligned with mullions

**Q:** 08 8000 2.3 and 2.4 calls for low E but does not say what kind. What is low E type or performance?

**A:** Low E to be Solar Control E-Coating

**Q:** 08 8000 2.6 Frosted Glass. Does this need to be 1" clear tempered low E #3 with film on surface #4?

**A:** Provide Low E on #2, Frosted film on #4

**Q:** W2 and W11 do not appear on the floor plan. They are on the elevation sheet A603 but not on the building.

**A:** Remove these elevations as they are duplicates

**Q:** All schools:

Doors D2 are interior wood doors. They call for 1 1/16" security glass. The only 1 1/16" security glass listed in the specification is the insulated version on the exterior entrances.

**A:** Change the D2 door security glazing to the following: Single Pane: 5/16-inch-thick overall laminated glass. 1/8-inch-thick heat strengthened laminated x .060 PVB interlayer x 1/8 thick heat strengthened glass.

**Q:** At reception B102. It shows a sliding transaction window. What is it?

**A:** Use Kawneer 8400 TL

**End of Addendum 2**