

**ADDENDUM
NO. 4**

September 17, 2024

**HANOVER COMMUNITY SCHOOLS – HIGH SCHOOL IMPROVEMENTS
AT BASEBALL AND SOFTBALL FIELDS AND RELATED WORK**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated August 28, 2024 by Gibraltar Design. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Page ADD 4-1 and attached Addendum No. 4 from Gibraltar Design dated September 16, 2024 and consisting of 1 page.

*****NOTE***** Alternate No. 5 and the Revised Bid Form were issued in Addendum 2. There were no changes to either in Addendum 3.

ADDENDUM FOUR

Addendum Four (AD.04) to the drawings and specifications prepared by Gibraltar Design and The Skillman Corporation for **Hanover CSC High School Baseball and Softball Fields and Related Work** for Hanover Community School Corporation, Cedar Lake, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and Addendum One, Two, Three, and include the appropriate content of same within their bid proposal.

SPECIFICATIONS

1. Specification Section 32 18 12 Synthetic Turf System

A. Revise Paragraph 2.2.C.1.b. to read as follows:

“b. Perimeter lines shall be tufted into the individual edge-line rolls.

- 1) Color 1: 100% Field Green – alternating with Color 2.
- 2) Color 2: 50% Field Green & 50% Summer Green – alternating with Color 1.
- 3) Color 3: Clay Red or Brown, depending on Manufacturer.”


B. Clarification of on-deck Logos' – will be white baseball stitch pattern set into Color 3 Turf color.

C. Clarification: Replacement Panels indicated in the Specification, it is intended that the Manufacturer/Installer provide Instructions to the Owner's staff for removing and installing the replacements panels. It is not the intent for the Contractors to provide future services in the bid for this scope of future work.

DRAWINGS

2. None.

Pages 1, inclusive, and No Full-Size Drawings, constitute the total makeup of **Addendum Four**.



Y:\23-144 Hanover CSC - HS Baseball Softball Fields and Related Work\Specs\Addendum 4\AD04.doc