ADDENDUM NO. 3

December 11, 2024

M.S.D. of Washington Township Centralized Service Center Phase 6c Site Improvements 8401 Westfield Blvd. Indianapolis, IN 46240

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications and the Drawings dated October 28, 2024, by Schmidt Associates. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 3-1, and Schmidt Associates Addendum No. 3 dated December 11, 2024, consisting of 1 page.

ADDENDUM NO. 3 DECEMBER 11, 2024

PREPARED BY SCHMIDT ASSOCIATES FOR:

OPERATION SERVICE CENTER WASHINGTON TOWNSHIP, M.S.D. OF

This Addendum consists of 1 Addendum page and 0 attachment pages totaling 1 page.

Acknowledge receipt of this Addendum by inserting its number on the Bid Form. Failure to do so may subject the Bid to disqualification. This Addendum is part of the Contract Documents.

Bidder is encouraged to verify with reprographer of record all Addenda issued (do not rely exclusively on third party plan room services).

PART 1 - CHANGES TO PRIOR ADDENDA (NOT APPLICABLE)

PART 2 - CHANGES TO THE PROJECT MANUAL (NOT APPLICABLE)

PART 3 - CHANGES TO THE DRAWINGS

Modifications described herein shall be incorporated in the Drawings. All other Work shall remain unchanged.

3.1 C-SERIES DRAWINGS

A. Drawing Number CL501

1. MODIFY Detail 15 Standard Asphalt Paving as follows:

"Compacted #53 Stone thickness 4"

Asphalt Base/Binding course 3"

Asphalt Top/Wearing Course 1.5" "

B. Drawing Number CL501

1. MODIFY Detail 16 Heavy Duty Asphalt as follows:

"Compacted #53 Stone thickness 6"

Asphalt Base/Binding course 3"

Asphalt Intermediate Course 1.5"

Asphalt Top/Wearing Course 1.5" "

END OF ADDENDUM 2

ADDENDUM NO. 2