

**ADDENDUM  
NO. 3**

February 12, 2026

Richland Bean Blossom Schools Roofing & Mechanical Renovations  
Various Schools Locations  
Ellettsville, IN 47429

**TO: ALL BIDDERS OF RECORD**

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated January 15, 2026, by Lancer Associates Architecture. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 3-1.

**A. SPECIFICATION SECTION - 01 12 00 MULTIPLE CONTRACT SUMMARY**

1. 3.03/A – Bid Category No. 1 – Roofing. Clarifications:
  - a. See Junior High School drawing sheet A201. In details 8 and 9, New Metal Flashing and Counter Flashing shall be 26-gauge 304 Stainless Steel.