

**ADDENDUM  
NO. 1**

**March 23, 2026**

**Chesterton High School Fieldhouse  
Improvements and Related Work  
Chesterton, IN 46304**

**TO: ALL BIDDERS OF RECORD**

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated March 6, 2026 by Gibraltar Design, Inc. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 1-1 and attached Addendum No. 1 from Gibraltar Design, Inc. dated March 20, 2026 and consisting of 1 page.

**SPECIFICATION SECTION 01 12 00 – MULTIPLE CONTRACT SUMMARY**

Under 3.03 Bid Categories:

**A. BID CATEGORY NO. 01 - GENERAL TRADES**

**1. Add:**

Clarification No. 10:

The **Bid Category No. 1 Contractor** is to include roof patching for mechanical curbs and equipment. All openings for equipment shall be coordinated with the **Bid Category No. 3** and **Bid Category No. 4 Contractor**.

**C. BID CATEGORY NO. 03 - HVAC**

1. **Add:**

Clarification No. 6:

The **Bid Category No. 1 Contractor** is to include roof patching for mechanical curbs and all other equipment. All openings for equipment shall be coordinated with the **Bid Category No. 3** and **Bid Category No. 4 Contractors**.

**D. BID CATEGORY NO. 04 – ELECTRICAL**

1. **Add:**

Clarification No. 2:

The **Bid Category No. 1 Contractor** is to include roof patching for mechanical curbs and all other equipment. All openings for equipment shall be coordinated with the **Bid Category No. 3** and **Bid Category No. 4 Contractors**.

## ADDENDUM ONE

**Addendum One (AD.01)** to the drawings and specifications prepared by Gibraltar Design for **Chesterton HS Fieldhouse Improvements and Related Work** for Duneland School Corporation, Chesterton, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and include the appropriate content of same within their bid proposal.

## SPECIFICATIONS

1. **Specification Section 08 11 13**                      **Standard Steel Doors and Frames**
  - A. Revise Paragraph 2.3.A. as follows: "A. Exterior Doors: ANSI A250.8, Level 2 (Heavy Duty), Model 2 (Seamless); 16 gage minimum thickness; galvanized."
  - B. Revise Paragraph 2.3.B. as follows: "B. Exterior Frames: 14 gage thick material; galvanized."
  - C. Revise Paragraph 2.4.A. as follows: "A. Exterior Doors: Polystyrene insulation for exterior doors. Provide minimum of U-Factor of 0.129."

## DRAWINGS

2. **None**

Page 1, inclusive, and NO Full-Size Drawings, constitute the total makeup of **Addendum One**.

