

**ADDENDUM
NO. 2**

March 27, 2026

**Chesterton High School Baseball/Softball Fields
Replacement and Related Work
Chesterton, IN 46304**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated March 6, 2026 by Gibraltar Design, Inc. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 2-1 and attached Addendum No. 2 from Gibraltar Design, Inc. dated March 26, 2026 and consisting of 1 page.

ADDENDUM TWO

Addendum Two (AD.02) to the drawings and specifications prepared by Gibraltar Design for **Chesterton HS Baseball and Softball Field Replacement and Related Work** for Duneland School Corporation, Chesterton, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received Addendum #1 and this Addendum and include the appropriate content of same within their bid proposal.

SPECIFICATIONS

1. **Specification Section 26 05 33.13** **Conduit for Electrical Systems**
 - A. Clarification: Confirming, conduits over 2" in size are to be Rigid Conduit's, not EMT.
2. **Specification Section 32 18 12** **Synthetic Turf System**
 - A. Add Paragraph 2.1.A.7. as follows: "7. SportTurf, Dalton, Georgia" as an acceptable manufacturer.
 - B. Add Paragraph 2.1.A.8. as follows: "8. Midwest Sport and Turf System, a TenCate Company, Plainfield, Illinois" as an acceptable manufacturer.
 - C. Add to Paragraph 2.6.A. "Jaypro Sports as an acceptable manufacturer for the Baseball and Softball Equipment indicated in this Paragraph.
 - D. Clarification: Contractors are reminded that the Specifications for Sub-Drainage and Synthetic Turf are tied functionally together as a complete system, and as such the warranty is also tied together.
 - E. Clarification: Question was asked where the replacement turf sizes for the bases, pitching mound, Homeplate areas, etc. is located in the Documents – please refer to Paragraph 3.5.E.

DRAWINGS

3. None

Page 1 inclusive and NO Full-Size Drawings, constitute the total makeup of **Addendum Two**.

