

ADDENDUM NO. 2

February 5, 2020

**Boone Meadow Elementary School Chiller Replacement
5555 S Main Street
Whitestown, IN 46075**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated December 10, 2019. Acknowledge receipt of the Addendum in the space provided on the Proposal Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 2-1.

A. SPECIFICATION SECTION 00 20 00 – Information Available to Bidders

- B. Pre-Award Meeting is scheduled for February 13, 2020 at 8:00 AM at The Skillman Corporation, 3834 S. Emerson Avenue, Bldg. A., Indianapolis, IN 46203.

B. SPECIFICATION SECTION 01 12 00 – Multiple Contract Summary

1. Paragraph 3.03 Bid Categories

A. Bid Category No. 1 – General Construction

Add the following General Clarifications:

7. Contractor shall provide all controls and integration necessary for a complete installation (ref. specification 23 64 23). Coordinate work for chiller controls with the existing temperature controls manufacturer/provider (Honeywell controls by E-Solutions).
8. Contractor shall ensure delivery of equipment to meet clearly specified critical project schedule. In order to advance the procurement process, Contractor shall submit standard Chiller Shop Drawings (ref. 23 64 23) with the Project Bid.