

ADDENDUM NO. 1

June 12, 2020

**WHEELER MIDDLE SCHOOL MEP BOILER REPLACEMENT PROJECT
Crown Point, IN 46307**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated May 26, 2020 by Gibraltar Design. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Pages ADD 1-1 and attached Addendum No. 1 from Gibraltar Design dated June 11, 2020 and consisting of 1 page.

ADDENDUM ONE

Addendum One (AD.01) to the drawings and specifications prepared by Gibraltar Design for **Wheeler Middle School MEP Boiler Replacement** for Crown Point Community School Corporation, Crown Point, Indiana.

All Contractors bidding on this project shall read all of the items covered below and shall comply with all of the requirements as set forth, including any necessary refinements or additions generated by this Addendum and required by the intent of the original contract documents. All Contractors shall acknowledge on their bid form that they have received this Addendum and include the appropriate content of same within their bid proposal.

SPECIFICATIONS

1. **Section 23 52 16** **Condensing Boilers and Accessories**
 - A. Remove "galvanized pipe" from acceptable combustion air intake piping material in paragraph 2.08.B.
 - B. Clarification: Boiler Combustion air intake piping is not required to be insulated.

DRAWINGS

2. **Sheet ME-201**

Hot Water System Piping Diagram: ADD 3" circuit setters on on supply lines connected to B-1 and B-2. Refer to specification section 23 21 33 for circuit setter requirements. Circuit setters shall be balanced to 126 GPM each.

Pages 1 through 1, inclusive, and No Drawings constitute the total makeup of Addendum One.


