

**ADDENDUM
NO. 5**

February 7, 2022

**Carmel High School Natatorium
520 Est Main Street
Carmel, IN, 46032**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated January 10, 2022, by Fanning/Howey Associates, Inc. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of Specification Sections 01 12 00

A. SPECIFICATION SECTION 01 12 00 – MULTIPLE CONTRACT SUMMARY

1. BID CATEGORY NO. 1 GENERAL TRADES

ADD:

Specification Section 09 77 10 – Framed Decorative Panel Systems

Clarification #67

In reference to the note #6 on S0.01: It is the intent that all footings including the pool as it is within the footprint of the pool addition shall bear on ground improvement by rammed aggregate piers as described in the note on the contract documents.