

**ADDENDUM
NO. 3**

April 7, 2022

**TIPPECANOE VALLEY HIGH SCHOOL ADDITIONS & RENOVATIONS
Akron, IN 46910**

TO: ALL BIDDERS OF RECORD

This Addendum forms a part of and modifies the Bidding Requirements, Contract Forms, Contract Conditions, the Specifications, and the Drawings dated March 10, 2022 by Fanning Howey Associates, Inc. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of pages ADD 3-1 through ADD 3-2.

A. SPECIFICATION SECTION 01 12 00 - MULTIPLE CONTRACT SUMMARY

1. BID CATEGORY NO. 1 - GENERAL TRADES

a. Add:

Clarification No. 32:

The **Bid Category No. 2 Contractor** shall provide all work associated with demolition and removal of existing masonry walls where new doors, windows, mechanical openings, and louvers are being added. The **Bid Category No. 2 Contractor** shall also provide lintels at these locations including patch and repair of masonry to match adjacent masonry.

Clarification No. 33:

The **Bid Category No. 2 Contractor** shall provide removal and reinstallation of "SALVAGED FACE BRICK" as indicated on the contract documents.

Clarification No. 34:

All concrete slabs are to be 4" thick per typical detail 6 on drawing sheet S3.03 unless otherwise noted.

2. **BID CATEGORY NO. 2 - MASONRY**

a. **Replace:**

Clarification No. 9:

The **Bid Category No. 2 Contractor** shall provide all work associated with demolition and removal of existing masonry walls where new doors, windows, mechanical openings, and louvers are being added. The **Bid Category No. 2 Contractor** shall also provide lintels at these locations including patch and repair of masonry to match adjacent masonry.

b. **Add:**

Clarification No. 11:

The **Bid Category No. 2 Contractor** shall provide removal and reinstallation of “SALVAGED FACE BRICK” as indicated on the contract documents.